

**HEALTH AND FOOD SAFETY DIVISION**

550 Landa Street
New Braunfels, TX 78130
Office: 830-221-4031 extension 5
Email: healthandfoodsafety@newbraunfels.gov
www.newbraunfels.gov

**Public
Swimming Pools and
Spas**

Facility Name:	Date:		
County: COMAL / GUADALUPE	Phone:		
Facility Address:	City: NEW BRAUNFELS		
Mailing Address:	State/Zip:		
Permit Number:	<input type="checkbox"/> Indoor	<input type="checkbox"/> Class A	<input type="checkbox"/> Class B
	<input type="checkbox"/> Outdoor	<input type="checkbox"/> Class C	<input type="checkbox"/> w/PIWF
<input type="checkbox"/> Spa	<input type="checkbox"/> Wade		
Inspection Type: <input type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Re-Inspection <input type="checkbox"/> Pre-Licensing <input type="checkbox"/> Other (specify):			

"X" indicates an alleged deficiency**"COS"** indicates corrected on-site**SWIMMING POOL OR WADE POOL**

1.Chlorine 1.0 to 8.0 ppm	
2.Bromine 3.0 to 10.0 ppm	
3.pH 7.0 to 7.8	
4.Cyanuric Acid: Max 100ppm	
5.Water clarity sufficient / no algae present	
6.DPD test kit in use is reliable and properly stored	
7.Deck & sidewall depth markers permanent with 4" numbers	
8.Markers at max. & min. depth, breakpoint & 2" depth intervals	
9.Minimum 2 entry / exits	
10.Depth markers no more than 25 feet	
11.Depth markers – feet and / or inches in 4" letters	
12.Wade pool 15ft from shallow /35ft from deepwater areas	
13.Wade pool fenced separately from pool / spa	
14.Wade pool with independent circulatory / sanitization system	

SPA

15.Chlorine 1.0 to 8.0 ppm	
16.Bromine 4.0 to 10.0 ppm	
17.pH 7.0 to 7.8	
18.Cyanuric acid outdoor spa (100 ppm or less)	
19.Water clarity sufficient / no algae	
20.Water temp 104F or less / spa thermometer available	
21.Emergency shutoff switch not <5' & not >10' from spa	
22.Manually operated 15min timer switch available to users	
23.Depth markers ft and / or inches in 4" letters	

ELECTRICAL

24.Pump(s) grounded and bonded	
25.Service electrical disconnect with in sight of pool / spa equipment	
26.ORP meter in use / mV reading 600 -900 mV	

SUCTION OUTLETS IN POOLS & SPAS

27.Suction outlet cover(s)/grate(s) intact and in place	
28.Dual Suction outlets or single suction outlet with SVRS	

CIRCULATION EQUIPMENT & MECHANICAL

29.Pump and filter functioning	
30.Circulation equipment has pump vacuum or vacuum pressure gauge	
31.Filter inlet and outlet gauge, and flowmeter in place	
32.Exposed piping labeled with function & directions of flow	
33.Written operation & maintenance instructions provided	
34.Pool/spa heater has TDLR operation certificate	
35.No user access to heater controls	
36.Skimmer basket not used to dispense chemicals	
37.Skimmer covers in place	

FILL WATER / DRINKING WATER / OPERATION

38.1x1 stripe on leading edge of benches & water lounges	
39.1x1 strip on leading edge of underwater / swimout steps	
40.Fill water public water supply	
41.Water distribution system protected against backflow	

BATH HOUSE & SANITARY FACILITIES

42.Facilities clean and sanitary	
43.Mirror shatter resistant & soap dispenser metal or plastic	
44.Toilet paper and holder provided	
45.Single use towels or hand dryer provided	
46.Covered waste receptables	
47.Floor slip resistant & sloped to floor drains	
48.Private gender specific facilities	

GLASS CONTAINERS & FOOD

49.Glass containers not in pool / spa yard	
50.Trash containers provided	

AQUATIC PLAY FEATURES

51.Wave pool has rope and float line restricting access to caisson wall	
52.Wave and Surf pools have 2 emergency shut off switches	

NO DIVING MARKERS & TRANSITION LINE

53.Min. 2 - 4" "NO DIVING" letters & symbol no more than 25' apart	
54.4"x 4" line on bottom at transition from shallow to deep	

SIGNS

55.Sign(s) visible to pool/spa user in all areas of pool/spa yard	
56.No Diving in 4" letters & symbol where applicable	
57.Warning – No Lifeguard on Duty as applicable - 4" letters	
58.In Case of Emergency Dial 911 – 4" letters	
59.Emergency "Phone" location sign visible in pool/spa yard	
60.Pool / spa maximum user load – 2" letters	
61.Emergency spa shut off – 2" letters	
62.Location of emergency phone or device when applicable – 2" letters	
63.Pets in pool / spa prohibited – 2" letters	
64.Persons less than 14yrs not in pool without adult supervision – 2" letters	
65.Extended breath holding activities prohibited – 2" letters	
66.Glass items not allowed – 2" letters	
67.Changing diapers within 6' of pool prohibited – 2" letters	
68.Do not swim if ill with diarrhea in past 2weeks – 2" letters	
69.Do not use spa if water temp. is over 104°F – 1" letters	

CLASS A & B AND ALL RESIDENTIAL YOUTH CAMPS

75.Minimum fence height 6 feet	
76.Fence designed to be difficult to climb	
77.Opening in or under fence do not allow passage of 4" sphere	
78.Gate(s) / door(s) continuously & directly supervised or locked	
79.Service gate not in use, closed and locked	

**CLASS C, D & DAY CAMPS POOLS / SPAS
NOT SUBJECT TO HSC757**

80. Minimum fence height 48" (4 feet)
81. Gate(s)/door(s) self-closing and self-latching
82. Openings do not allow passage 4" sphere
83. Hardware on gates and doors at least 3-1/2ft above ground
84. Gate not propped open
85. Gate or door open outward away from pool / spa
86. Service gate not in use closed and locked
87. No building in pool/spa yard with exits out of pools/spa yard

ALL POOLS & SPAS SUBJECT TO HSC757

88. Minimum height 48"	
89. Gate(s)/door(s) not propped open	
90. Service gate not in use, closed and locked	
91. Latch either on outside of gate & min 60" above the ground	
92. Latch inside gate 3" below the top of gate or door; and	
93. No openings exceeding 1/2 "within 18" of the latch	
94. Latch min 42" above ground & opens with key, card or comb	
95. Horizontals at least 36" apart with gaps less than 4"	
96. After 1/1/94 horizontals $\geq 45"$ apart/gaps $\leq 4"$, or	
97. After 1/1/94 horizontals $< 45"$ gaps no greater than 1-3/4"	
98. After 1/1/94 , No chain link fencing	
99. After 1/1/94 , gate(s) / door(s) open outward	
100. After 1/1/94 No fence cutouts w/ gaps greater than 1-3/4"	

Signs that are in bold letters are not required unless signs are replaced after 01/01/2021 or the facility constructed on or after 01/01/2021. A complete list of all new sign requirements can be found at: <https://dshs.texas.gov/poolspa/guidance.aspx>.

Comments: _____

Inspected by(signature):	Owner/Operator(signature):
Printed Name:	Printed Name: