



AMENDMENT OF SOLICITATION

City of New Braunfels
Purchasing
551 Landa Street
New Braunfels, Texas 78130

1. Solicitation No. and Title CSP 24-039 McQueeney Road Rehabilitation	2. Amendment No. 2	3. Effective Date of this Action September 17, 2024
4. Name and Address of Offeror or Contractor	5. For Information Call: (No collect calls or Fax offers accepted) Purchasing: Barbara Coleman Phone No.: 830-221-4389 Email: Bcoleman@newbraunfels.gov	6. Amount of Contract/Order is: Increased by: Decreased by: New Total: <input type="checkbox"/> Unchanged

7. THIS BLOCK APPLIES TO AMENDMENTS OF SOLICITATIONS ONLY:

The above numbered solicitation is amended as set forth in Block 8 below.

The date and time specified for receipt of offers IS NOT extended.

THE DATE AND TIME SPECIFIED FOR RECEIPT OF OFFERS IS CHANGED TO: **SEPTEMBER 26, 2024 at 3:00 pm**

Offerors must acknowledge receipt of this amendment prior to the date and time specified in the solicitation or as amended, by one of the following methods:

- (i) By completing Blocks 4 and 9.a,b,c and returning this Addendum in the number of copies specified for the solicitation;
- (ii) By acknowledging receipt of this Addendum on each copy of the bid submitted; or,
- (iii) By separate letter, telegram, or fax referencing the solicitation and addendum.

If by virtue of this Addendum offeror desires to change an offer already submitted, such change may be made by letter, telegram, or fax, provided each such notice makes reference to the solicitation AND this Addendum, and is received prior to the date and time specified.

NOTICE: NON-RECEIPT OF YOUR OFFER AND THIS ADDENDUM AT THE DESIGNATED PLACE WITHIN THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.

8. DESCRIPTION OF CHANGES -

a. This Amendment #2 is issued to provided the following clarifications and support to questions received after posting of Amendment #1.

-Additional Questions and Answers.

• Plans are showing a Retaining Wall on Sh. 22, are we looking for a type F1-3 footing for the sidewalk?

Answer: Yes, it is an F2 footing. There is no pay item for it. The footing and the wall are incidental to the sidewalk quantities.

• For the driveways, are they supposed to be 5" thick; I do not see a detail for it.

Answer: Yes, the driveways are 5" thick. See attached City of New Braunfels standard detail ST-014.1 and .2.

• The Elevated sidewalk opening is 12-ft but where the sidewalk goes over the drain, there is not a set dimension. Could the engineer give us the dimension from top of sidewalk to top of drain and the width. See attached sheet.

Answer: The opening under the sidewalk is 12' clear, centered on the existing channel. The bottom of the sidewalk shall be 6" above the top of the channel.

• On sheet 4 there is a detail for sidewalk with the ribbon curb and also a detail of a sidewalk with a thickened edge, but I cannot locate where this is supposed to be installed. Could you please verify where these items are to be installed?

Answer: Based on the details on sheet 4, the locations are noted by the stations shown under each detail.

NOTE THAT THE DATE RESPONSES ARE DUE IS CHANGED TO SEPTEMBER 26, 2024 AT 3:00 PM.

Except as provided herein, all terms and conditions of the document referenced above remain unchanged and in full force and effect.

9a. SIGNATURE OF OFFEROR OR CONTRACTOR	10. CITY OF NEW BRAUNFELS, TEXAS	
9b. PRINTED NAME AND TITLE	9c. DATE	9/17/2024 Date