

Changes to the City of New Braunfels Drainage and Erosion Control Design Manual

Issued by City Engineer, Jim Klein on 05/03/2011

Approved on 05/03/2011 by unanimous vote of Planning and Zoning Commission

Section 2.1.3 B 1. is changed to read as follows:

Mitigation through detention, retention, or some other technique must be designed, constructed and maintained to reduce the post-development discharge rate to below that of pre-development for the 2-year, 10-year, 25-year, and 100-year design storms. Participation in neighborhood or regional mitigation is an acceptable option.

Section 2.5.2 A. is changed to read as follows:

Stormwater retention or detention facilities must reduce peak flows from the 2-year, 10-year, 25-year, and 100-year 24-hour storms such that these peak flows are no greater than under pre-development conditions.